



All dimensions shown are in millimetres

Test pressure: **22.5 BAR**
 Max working pressure: **15 BAR**
 Max working temperature: **90° C**
 All stainless steel construction: **30x30x1.5mm square headers**
dia 18mm x 1.5mm round tubes
 Connections: **½ inch BSP underside tappings**

Heat output determined in accordance with EN 442

Manufactured in Russia for Bisque

Model	Output $\Delta T=50K$ Watts	Output $\Delta T=60K$ Watts	n	Water Content litres	Weight kg	Height $\pm 2mm$	Length $\pm 2mm$	Tapping Centres $\pm 2mm$	Fixing Centres $\pm 5mm$
OLA 60-50	145	181	1.20	1.5	4	600	480	450	450
OLA 90-30	158	199	1.27	1.7	4	900	300	270	270
OLA 90-50	174	218	1.24	2.0	5	900	480	450	450
OLA 120-30	204	256	1.26	2.3	5	1200	300	270	270
OLA 120-50	232	292	1.27	2.7	7	1200	480	450	450
OLA 120-65	282	354	1.25	3.0	8	1200	630	600	600
OLA 155-30	263	331	1.26	3.0	6	1575	300	270	270
OLA 155-50	332	416	1.24	3.6	8	1575	480	450	450

Tools & Material Required

Suitable valves
 PTFE tape
 Silicone thread sealant
 Tape measure
 Allen key - 13mm & 12mm (when installing Bisque valves)
 Spanner - 13mm & 14mm
 Screwdriver - flathead
 Pliers
 Electric drill
 Masonry drill bit
 Spirit level
 Stepladder (for taller radiators)

Key	Component	Qty
A	Air Vent - 1/2"	1
B	Wall Plug	4
C	Bracket	4
D	Screw - Hex Head, 6mm dia x 60mm	4
E	Washer	4
F	Grub Screw	4
G	Allen Key	1

Assembly Instructions

Sufficient PTFE tape must be applied to valve-tail threads prior to their installation.
 Silicone thread sealant should be applied to all threaded components manufactured with 'O-rings'.

- Fit valve tails, using correct size Allen key.
- Fit air vent (A).
- Accurately mark out bracket holes on wall using spirit level.
- Drill four holes to a minimum depth of 65mm & insert wall plugs (B).
- Screw brackets (C) into wall plugs (B) with 6mm diameter x 70mm screws (D) & washers (E).
- Offer radiator up to wall and slide square posts on the rear of the radiator into brackets (C).
- Secure radiator in position by tightening Allen headed screw (F) with Allen key (G).
- Plumb radiator to heating circuit with flow opposite air vent.

This radiator should be installed onto a central heating system that has been cleaned/flushed and contains water treatment and inhibitors in accordance with BS7593.

